TORKEL 840/860Battery Load Units



- Batteries can be tested "in service"
- Unit adjusts to include load currents in the test parameters
- User adjustable alarm and shutdown points to avoid excessive discharge
- Easily expandable for larger battery banks using TXL extra load units
- View test parameters/results "real time" as testing progresses using TORKEL WIN software (optional)
- Easily save results to a PC for analysis, report generation and storage

Description

Batteries in power plants and transformer substations must provide the equipment they serve with standby power in the event of a power failure. Unfortunately, however, the capacity of such batteries can drop significantly for a number of reasons before their calculated life expectancy is reached. This is why it is so important to check batteries at regular intervals, and the only reliable way of measuring battery capacity is to conduct a discharge test.

TORKELTM 840 - UTILITY is used for battery systems ranging from 12 to 250 V – often encountered in switchgear and similar equipment. Discharging can take place at up to 110 A, and if higher current is needed, two or more TORKEL 840 units or extra load units, TXL, can be linked together. Tests can be conducted at constant current, constant power, constant resistance or in accordance with a preselected load profile.


TORKEL 860 - MULTI is designed primarily for people who travel from place to place to maintain battery systems having different voltages. It features excellent discharging capacity plus a broad voltage range and outstanding portability – a unique combination.

TORKEL 860 is used for systems ranging from 12 to 480 V, and discharging can proceed at up to 110 A. If higher current is desired, two or more TORKEL 860 units or extra load units, TXL, can be linked together. Discharging can take place at constant current, constant power, constant resistance or in accordance with a preselected load profile.

Application example

Testing can be carried out without disconnecting the battery from the equipment it serves. Via a DC clamp-on ammeter, TORKEL measures total battery current while regulating it at a constant level.

The TORKEL is connected to battery, the current and the voltage alarm level are set. After starting the discharge TORKEL keeps the current constant at the preset level. When the voltage drops to a level slightly above the final voltage, TORKEL issues an alarm. If the voltage drops so low that there is a risk for deep discharging the battery, TORKEL shuts down the test. The total voltage curve and the readings taken at the end of the test are stored in TORKEL Later, using the TORKEL Win program (optional), you can transfer these readings to your computer for storage, printout or export. If your PC is connected to TORKEL during the test, TORKEL Win builds up a voltage curve on the screen in real time and displays the current, voltage and capacity readings. You can also control the test using TORKEL Win.



Features and benefits

- 1. Display
- External measurement input used to measure current in an external path by means of a clamp-on ammeter or a current shunt
- 3. Keys for operation and settings.
- Alarm output equipped with a relay contact for triggering an external alarm device.
- Start/Stop input used for starting and stopping discharging from an external device. Galvanically isolated.
- 6. Indicating lamps. Operating, Stop/Limit
- TXL output used for control of TXL Extra Loads. Galvanically isolated
- 8. Serial port used for connection to a PC or other controlling equipment.
- 9. Voltage controlled circuit breaker that connects / disconnects the loading circuits in TORKEL from the battery.
- 10. Positive current connection for battery being tested.
- 11. Input for sensing voltage at the battery terminals.
- 12. Negative current connection for battery being tested.
- 13. Mains connector, equipped with ON/OFF switch.



Application examples with TORKEL/TXL systems


TORKEL and TXL can be combined into systems to match up for different battery capacities. These resistive extra loads do not perform any regulating functions. They are designed for use together with TORKEL Battery Load Units. Their purpose is to provide higher load currents for use in constant current or constant power tests. Together, TORKEL and the TXL Extra Loads form a system that can discharge batteries with currents of up to several kA. TXL Extra Loads are connected directly to the battery, and TORKEL measures the total current using a clamp-on ammeter.

TXL Extra Loads are shut down automatically when TORKEL is stopped.

	TORKEL/TXL-systems examples				
	Max. constant current	Number of	Number of		
	(A)	TORKEL-units	TXL-units		
	TORKEL 840/860 + TXL83	0, 24 V battery (12	cells)¹)		
	263	1	1		
	670	2	2		
	1005	3	3		
	TORKEL 840/860 + TXL85	0, 48 V battery (24	cells)1)		
	264	1	1		
	909	2	3		
	TORKEL 840/860 + TXL87	0, 110 V battery (5	4 cells) ¹⁾		
4	188	1	1		

188	1	1
532	2	4
845	2	8

- 1) Discharge from 2.15 V to 1.8 V per cell
- 2) Discharge from 2.15 to 1.75 V per cell



TORKEL and the extra load TXL

Megger.

Specifications TORKEL 840/860

Specifications are valid at nominal input voltage and an ambient temperature of +25°C, (77°F). Specifications are subject to change without notice.

Environment

Application field The instrument is intended for use in

high-voltage substations and industrial

environments.

Temperature

 0° C to +40°C (32°F to +104°F) Operating Storage & transport -40°C to +70°C (-40°F to +158°F) Humidity 5% - 95% RH, non-condensing

CE-marking

EMC 2004/108/EC LVD 2006/95/EC

General

Mains voltage 100 - 240 V AC, 50/60 Hz

Power consumption 150 W

(max)

Protection Thermal cut-outs, automatic overload

protection

Dimensions

Instrument 210 x 353 x 700 mm

(8.3" x 13.9" x 27.6")

265 x 460 x 750 mm Transport case

(10.4" x 18.1" x 29.5")

Weight 21.5 kg (47.4 lbs)

38 kg (83.8 lbs) with accessories and

transport case.

Display

English, French, German, Spanish, Swed-Available languages

Measurement section

Current measurement

0.0 - 2999 A Display range

 $\pm (0.5\% \text{ of reading } +0.2 \text{ A})$ Basic inaccuracy

Resolution Internal current measurement

Range 0 - 300 A

Input for clamp-on ammeter

Range 0 - 1 V

Software settable, 0.3 to 19.9 mV/A mV/A-ratio

Input impedance >1 MΩ

Voltage measurement Display range 0.0 - 60 V

Basic inaccuracy \pm (0.5% of reading +0.1 V)

Resolution 01V

Display range 0.0 - 500 V

Basic inaccuracy \pm (0.5% of reading +1 V)

0.1 V Resolution

Time measurement

Basic inaccuracy ±0.1% of reading ±1 digit

Load section

Max. battery voltage 288 V DC (TORKEL 840)

480 V DC (TORKEL 860)

110 A Max. current Max. power 15 kW

Load patterns Constant current, constant power, con-

stant resistance, current or power profile

Current setting 0-110.0 A (2999.9 A) 1)

0-15.00 kW (299.99 kW) 1) Power setting

0.1-2999.8 Ω Resistance setting

Battery voltage range, 4 ranges, selected automatically at start TORKEL 840

of test

Battery voltage range, 5 ranges, selected automatically at start TORKEL 860

of test

Stabilization (For inter- $\pm (0.5\% \text{ of reading } \pm 0.5 \text{ A})$

nal current measurement)

		Battery voltage	Highest permissible current	Resistor ele- ment (Nominal values)
	Range 1	10 – 27.6 V	110 A	0.165 Ω
	Range 2	10 – 55.2 V	110 A	0.275 Ω
	Range 3	10 – 144 V	110 A	0.55 Ω
Ô	Range 4	10 – 288 V	55 A	3.3 Ω
	Range 5 ²⁾	10 – 480 V	55 A	3.3 Ω
			(max nower 15 kW)	

Maximum value for a system with more than one load unit

Inputs, maximal values

EXTERNAL 1 V DC, 300 V DC to ground. Current CURRENT shunt should be connected to the nega-**MEASUREMENT** tive side of the battery

START/STOP Closing/opening contact

Closing and then opening the contact will start/stop Torkel. It is not possible to keep the contacts in closed position.

Delay until start 200 - 300 ms Stop delay 100 - 200 ms

480 V DC, 500 V DC to ground Battery **VOLTAGE SENSE** 480 V DC, 500 V DC to ground

SERIAL < 15 V

ALARM 250 V DC 0.28 A

28 V DC 8 A 250 V AC 8 A

Outputs, maximal values

START/STOP 5 V. 6 mA TXI Relay contact SERIAL < 15 V **ALARM** Relay contact

²⁾ TORKEL 860

Megger.

Discharging capacity, examples

12 V battery (6 cells) 3)

12 v battery (6 cells) 3					
Final voltage	Constant current	Constant power			
1.80 V/cell (10.8 V)	0 – 50.0 A	0 – 0.54 kW			
1.75 V/cell (10.5 V)	0 – 49.0 A	0 – 0.51 kW			
1.67 V/cell (10.0 V)	0 – 46.0 A	0 – 0.46 kW			
24 V battery (12 cells)	3)				
1.80 V/cell (21.6 V)	0 – 110 A	0 – 2.37 kW			
1.75 V/cell (21.0 V)	0 – 110 A	0 – 2.31 kW			
1.60 V/cell (19.2 V)	0 – 100 A	0 – 1.92 kW			
48 V battery (24 cells)	3)				
1.80 V/cell (43.2 V)	0 – 110 A	0 – 4.75 kW			
1.75 V/cell (42.0 V)	0 – 110 A	0 – 4.62 kW			
1.60 V/cell (38.4 V)	0 – 110 A	0 – 4.22 kW			
110 V battery (54 cells) 3)				
1.80 V/cell (97.2 V)	0 – 110 A	0 – 10.7 kW			
1.75 V/cell (94.5 V)	0 – 110 A	0 – 10.4 kW			
1.60 V/cell (86.4 V)	0 – 110 A	0 – 9.5 kW			
120 V battery (60 cells) 3)				
1.80 V/cell (108 V)	0 – 110 A	0 – 11.9 kW			
1.75 V/cell (105 V)	0 – 110 A	0 – 11.5 kW			
1.60 V/cell (96 V)	0 – 110 A	0 – 10.5 kW			
220 V battery (108 cell	ls) ³⁾				
1.80 V/cell (194 V)	0 – 55 A	0 – 10.7 kW			
1.75 V/cell (189 V)	0 – 55 A	0 – 10.4 kW			
1.60 V/cell (173 V)	0 – 51.0 A	0 – 8.82 kW			
240 V battery (120 cell	s) ³⁾				
1.80 V/cell (216 V)	0 – 55 A	0 – 11.9 kW			
1.75 V/cell (210 V)	0 – 55 A	0 – 11.5 kW			
1.60 V/cell (192 V)	0 – 55 A	0 – 10.5 kW			
UPS battery (180 cells) 3) (TORKEL 860)					
1.70 V/cell (306 V)	0 – 38 A	0 – 15 kW			
1.60 V/cell (288 V)	0 – 38 A	0 – 15 kW			
UPS battery (204 cells					
1.80 V/cell (367 V)	0 – 34 A	0 – 15 kW			
1.60 V/cell (326 V)	0 – 34 A	0 – 15 kW			
3) 2.15 V per cell when test star	ts				

Specifications TXL830/850/870/890

Specifications are valid at nominal input voltage and an ambient temperature of +25°C, (77°F). Specifications are subject to change without notice.

Environment

Environment	
Application field	The instrument is intended for use in high-voltage substations and industrial environments.
Temperature	
Operating	0°C to +40°C (32°F to +104°F)
Storage & transport	-40°C to +70°C (-40°F to +158°F)
Humidity	5% – 95% RH, non-condensing
CE-marking	
EMC	2004/108/EC
LVD	2006/95/EC

General

Mains voltage	100 – 240 V AC, 50/60 Hz
Power con- sumption	75 W (max)
Protection	Thermal cut-outs, automatic overload protection
Dimensions	
Instrument	210 x 353 x 600 mm (8.3" x 13.9" x 23.6")
Transport case	265 x 460 x 750 mm (10.4" x 18.1" x 29.5")
Weight	13 kg (28.7 lbs) 21.4 kg (47.2 lbs) with transport case
Cable sets	
for TXL830/850	2 x 3 m (9.8 ft), 70 mm2, 270 A, with cable lug. Max. 100 V. 5 kg (11 lbs)
for TXL870/890	2 x 3 m (9.8 ft), 25 mm2, 110 A, with cable clamp/lug. Max. 480 V. 3 kg (6.6 lbs)
and the second second	

Load section

Load section				
	TXL830	TXL850	TXL870	TXL890
Voltage (DC) max.	28 V	56 V	140/280 V	230/480 V
Current max.	300 A	300 A	112 A at 140 V 56 A at 280 V	63 A at 230 V 32 A at 480 V
Power max.	8.3 kW	16.4 kW	15.8 kW	15.4 kW
Internal resista				
Position 1	TXL830	TXL850	TXL870	TXL890
Current	0.275Ω	0.55 Ω	4.95 Ω	14.10 Ω
100 A	at 27.6 V (12 x 2.3 V)	at 55.2 V (24 x 2.3 V)	_	-
78.5 A	at 21.6 V (12 x 1.8 V)	at 43.2 V (24 x 1.8 V)	-	-
50.1 A	-	-	at 248.4 V (108 x 2.3 V)	-
39.2 A	-	-	at 194.4 V (108 x 1.8 V)	-
32.3 A	-	-	_	at 469.2 V (204 x 2.3 V)
26.0 A	-	-	_	at 367.2 V
				(204 x 1.8 V)
Position 2	TXL830	TXL850	TXL870	(204 x 1.8 V) TXL890
Position 2 Current	TXL830 0.138 Ω	TXL850 0.275 Ω	TXL870 2.48 Ω	
				TXL890
Current	0.138 Ω	0.275 Ω at 55.2 V		TXL890
Current 200 A	0.138 Ω at 27.6 V	0.275 Ω at 55.2 V (24 x 2.3 V) 43.2 V		TXL890 7.05 Ω - - at 248.4V (108 x 2.3 V)
Current 200 A 156 A	0.138 Ω at 27.6 V	0.275 Ω at 55.2 V (24 x 2.3 V) 43.2 V		TXL890 7.05 Ω - at 248.4V
Current 200 A 156 A 35.2 A	0.138 Ω at 27.6 V	0.275 Ω at 55.2 V (24 x 2.3 V) 43.2 V		TXL890 7.05 Ω - at 248.4V (108 x 2.3 V) at 194.4V
Current 200 A 156 A 35.2 A 27.8 A	0.138 Ω at 27.6 V at 21.6 V - TXL830 0.092 Ω	0.275 Ω at 55.2 V (24 x 2.3 V) 43.2 V (24 x 1.8 V) TXL850 0.184 Ω	2.48 Ω	TXL890 7.05 Ω - at 248.4V (108 x 2.3 V) at 194.4V (108 x 1.8 V)
Current 200 A 156 A 35.2 A 27.8 A Position 3	0.138 Ω at 27.6 V at 21.6 V - TXL830	0.275 Ω at 55.2 V (24 x 2.3 V) 43.2 V (24 x 1.8 V) TXL850	2.48 Ω TXL870	TXL890 7.05 Ω - at 248.4V (108 x 2.3 V) at 194.4V (108 x 1.8 V) TXL890
Current 200 A 156 A 35.2 A 27.8 A Position 3 Current	0.138 Ω at 27.6 V at 21.6 V - TXL830 0.092 Ω	0.275 Ω at 55.2 V (24 x 2.3 V) 43.2 V (24 x 1.8 V) TXL850 0.184 Ω at 55.2 V	2.48 Ω TXL870	TXL890 7.05 Ω - at 248.4V (108 x 2.3 V) at 194.4V (108 x 1.8 V) TXL890
Current 200 A 156 A 35.2 A 27.8 A Position 3 Current 300 A	0.138 Ω at 27.6 V at 21.6 V - TXL830 0.092 Ω at 27.6 V	0.275 Ω at 55.2 V (24 x 2.3 V) 43.2 V (24 x 1.8 V) - TXL850 0.184 Ω at 55.2 V (24 x 2.3 V) 43.2 A	2.48 Ω TXL870	TXL890 7.05 Ω - at 248.4V (108 x 2.3 V) at 194.4V (108 x 1.8 V) TXL890
Current 200 A 156 A 35.2 A 27.8 A Position 3 Current 300 A 235 A	0.138 Ω at 27.6 V at 21.6 V - TXL830 0.092 Ω at 27.6 V	0.275 Ω at 55.2 V (24 x 2.3 V) 43.2 V (24 x 1.8 V) - TXL850 0.184 Ω at 55.2 V (24 x 2.3 V) 43.2 A	2.48 Ω - - TXL870 1.24 Ω - at 124.2 V	TXL890 7.05 Ω - at 248.4V (108 x 2.3 V) at 194.4V (108 x 1.8 V) TXL890
Current 200 A 156 A 35.2 A 27.8 A Position 3 Current 300 A 235 A 100 A	0.138 Ω at 27.6 V at 21.6 V - TXL830 0.092 Ω at 27.6 V	0.275 Ω at 55.2 V (24 x 2.3 V) 43.2 V (24 x 1.8 V) - TXL850 0.184 Ω at 55.2 V (24 x 2.3 V) 43.2 A	2.48 Ω - - TXL870 1.24 Ω - at 124.2 V (54 x 2.3 V) at 97.2 V	TXL890 7.05 Ω - at 248.4V (108 x 2.3 V) at 194.4V (108 x 1.8 V) TXL890
Current 200 A 156 A 35.2 A 27.8 A Position 3 Current 300 A 235 A 100 A 78.4 A	0.138 Ω at 27.6 V at 21.6 V - TXL830 0.092 Ω at 27.6 V	0.275 Ω at 55.2 V (24 x 2.3 V) 43.2 V (24 x 1.8 V) - TXL850 0.184 Ω at 55.2 V (24 x 2.3 V) 43.2 A	2.48 Ω - - TXL870 1.24 Ω - at 124.2 V (54 x 2.3 V) at 97.2 V	TXL890 7.05 Ω at 248.4 V (108 x 2.3 V) at 194.4 V (108 x 1.8 V) TXL890 3.52 Ω at 248.4 V

Megger.

Optional accessories

TORKEL Win



- Shows the complete voltage curve
- Last recorded time, voltage, current and discharged capacity
- Scroll-window for all recorded values
- Remote control of TORKEL
- Report functions

Note: TORKEL Win PC SW is delivered with TORKEL but an optional license (SW key) must be ordered to run it together with a TORKEL.

Extra loads



Four extra loads available: TXL830, TXL850, 870 and TXL890

Cables



Cable set (GA-00554)

Clamp-on-ammeters



- Clamp-on ammeters, 200 A DC and 1000 A DC
- To measure current in circuit outside TORKEL

BVM



- Automates battery voltage measurement during capacity tests
- "Daisy-chain" design allows expandability up to 120 units
- High accuracy and stability for precise data collection
- Integrates with TORKEL Win (included) and PowerDB Test
 Data Management software (freeware)
- For complete information see the BVM data sheet

Sensing leads



Sensing lead set (GA-00210)

Included accessories

Cable set



Cable set GA-00550

Ordering information

Item	Art. No.
TORKEL 840	BS-49094
TORKEL 860	BS-49096

Included accessories

Mains cable

Cable set, GA-00550

CD with TORKEL Win (SW locked for use together with a TORKEL)

Transport case, GD-00054

Optional accessories

TORKEL Win

Including:

CD with TORKEL Win

SW license (SW key) for one TORKEL unit

USB cable and USB to RS232 converter

Note: If you buy TORKEL Win for use together with a TORKEL you already have, please state the serial No.

of your TORKEL. BS-8208X

TXL830 Extra load

Incl. Cable set GA-00554 (max 28 V), Transport case BS-59093

TXL850 Extra load

Incl. Cable set GA-00554 (max 56 V), Transport case BS-59095

TXL870 Extra load

Incl. Cable set GA-00550 (max 280 V), Transport case BS-59097

TXL890 Extra load

Incl. Cable set GA-00550 (max 480 V), Transport case BS-59099

1	Item	Art. No.
	Cable set for TXL830 and TXL850 2 x 3 m, 70 mm², with cable lug. Max 100 V 270 A. Weight: 5.0 kg (11 lbs)	GA-00554
	Cable set for TXL870 and 890 2 x 3 m, 25 mm², with cable clamp. Max 480 V 110 A. Weight: 3.0 kg (6.6 lbs)	GA-00550
	Extension cable set 2 x 3 m, 25 mm². Max 480 V 110 A Weight: 3.0 kg (6.6 lbs)	GA-00552
	Sensing lead set Cable set for measuring voltage at battery terminals. 2 x 5 m (16.4 ft)	GA-00210
	DC clamp-on ammeter, 200 A To measure current in circuit outside TORKEL	XA-12992
	DC clamp-on ammeter, 1000 A To measure current in circuit outside TORKEL	XA-12990
	BVM Including: TORKEL Win license (SW key) for one TORKEL Dolphin clips, Power & signal connector, Power supply, Connection cables and Carrying case	
	BVM150, System of 16 BVM units With TORKEL Win software	CJ-59092
	With PowerDB software	CJ-59192
	BVM300, System of 31 BVM units With TORKEL Win software	CJ-59093
	With PowerDB software	CJ-59193
	BVM600, System of 61 BVM units With TORKEL Win software	CJ-59096
	With PowerDB software	CJ-59196

Postal address

Megger Sweden AB Box 724 SE-182 17 DANDERYD SWEDEN

Visiting address Megger Sweden AB Rinkebyvägen 19 SE-182 36 DANDERYD SWEDEN

T +46 8 510 195 00 F +46 8 510 195 95

seinfo@megger.com www.megger.com Registered to ISO 9001 and 14001 Megger is a registered trademark

Printed matter:
Art.No. ZI-BS02E • Doc. BS2643EE • 2015
TORKEL-840-860_DS_en_V08
Subject to change without notice.

